1	2	3	4	5	6
	* 1991 - 92				
6.	*Karneng HEP (Arunachal)	600 (4x150)	974.22	1990	11.24
7.	*Srisailam LBPH (AP)	900 (6 x 150)	1166.66	1990	1.25
8.	1992-93 *Purulia Pump Storage HEP (WB)	900 (4x225)	1456.56	1991	10.74
9.	*Sawalkot HEP (NTPC) (J&K)	600 (3x200)	1854.55	1991	9.46
10.	*Bakreshwar TPP (WBPDCL (W.B.) * 1993 - 94	1050 (5x210)	3052.55	1992	0.82
11.	*Teesta Stage-VHEP (Sikkim)	510 (3x170)	1925.44	1993	2.00
12.	*Dabhol CCGT Dabhol Power Company (Maharashtra)	695(nett)	2857.6 (Completed Cost)	1997	N.A.
13.	*Paguthan CCGT (MS GTECL) (Gujarat)	654.7	2298.14 (Completed Cost)	1996	N.A.
14.	*Omkareshwar MPP(H) (MP) * 1994 - 95	520 (8x65)	1216.95	1993	23.66
15	^Parbati HEP-II (Himachal Pradesh)	800 (4x200)	2151.78	1994	12.26
16.	*Bhadravati TPP (Central India Power Co. (Maharashtra) * 1995 - 96	1072 (2x536)	5187.00 (Completed Cost)	1998	N.A.
17.	**Hazira CCGT (Essar Power Ltd.) (Gujarat)	515	1666.56 (Completed Cost)	1996	N.A.

* Public Sector Projects
** Private Sector Projects
N.A. Not available Separately

Explosion in Turbo-Gcncrator in NTPC's Talchcr Plant

*134. SHRI NILOTPAL BASU:
SHRI DIPANKAR MUKHERJEE:

Will the Minister of POWER be pleased to state:

(a) whether there was any explosion in 500 MW Turbo-generator in NTPC's Talcher Plant in October, 1995;

(b) if so, whether the same occurred before the guaranteed run;

(c) the number of hours run and total generation before the explosion;

(d) the i approximate replacement and repair cost and whether the same is being done free of cost by the foreign supplier;

(e) whether loss of generation during shut down period is being compensated by the supplier, if not the reasons therefor;

(f) whether an independent enguiry by Central Electricity Authority is being conducted, if not, the reasons therefor; and

(g) the likely date of recommissioning of the plant?

THE MINISTER OF POWER (SHRI N.K.P. SALVE): (a) A mechanical failure of cooling fan of the generator caused damage to the generator in the first 500 MW Unit in the Talcher Thermal Power Project of National Thermal Power Corporation (NTPC) on 4th October, 1995.

(b) Yes, Sir.

(c) The Unit was synchronised on 19.2.1995 and had logged a total of 2845 running hours before the failure occurred and had generated 705.804 Million Units.

(d) on the basis of preliminary assessment of the damage the repair/ replacement work has been taken up by the supplier without any cost implication to NTPC.

(e) As per the provision of the contract, contractor is not responsible for loss of generation.

(0 Yes. Sir.

(g) The unit is expected to be recommissioned in March, 1996.

News item captioned "A Government Backed Scam for all Seasons"

*135. SHRI PRAMOD MAHAJAN:
SHRI VIREN J. SHAH:

Will the Minister of FINANCE be pleased to state:

(a) whether Government's attention has been drawn to a report published in the Times of India (Business Times) Bombay edition of February 6, 1995 under the heading "A Government backed scam for all seasons";

(b) if so, what are the facts and details of various' issues raised in the above report;

(c) whether Government have made any enquiry into the various issues raised and allegations made in the above report; and

(d) if so, what are the details thereof and what action Government have so far taken in the matter?

THE MINISTER OF STATE IN THE MINISTRY OF FINANCE (DR. DEBIPROSAD'PAL): (a) to (d) The news item captioned "A Government backed scam for All Seasons" in the Times of India dated 6th Feb., 1995 regarding All Seasons Foods Ltd., inter-alia, raised the following issues:—

(i) Waiver granted by the erstwhile controller of Capital Issues to the Rights issue by the Company in 1990-91;

(ii) Withdrawal by certain banks of the underwriting commitment given to the Issue; and

(iii) Other irregularities by the company such as non-payment of dividents, mis-statement in the prospectus regarding financial performance, failure to hold Annual General Meeting within the stipulated time, etc.

The right issue by all Season Foods Ltd., of fully convertible Debentures amounting to Rs. 10.37 crores opened on